

Barrington School District

311 Reading Avenue Barrington, New Jersey 08007
(856) 547-8467 office (856) 547-5533 fax

Mr. Anthony Arcodia
Superintendent

Mr. Samuel Dutkin
School Business Administrator

June 30, 2017

Results of Lead Testing in Water in the Barrington School District

On July 13, 2016 the New Jersey State Board of Education adopted regulations requiring testing for lead in drinking water in public schools throughout the state. The regulations require "testing for lead in all drinking water outlets within 365 days of the effective date of the regulations," which was July 13, 2016. All districts are directed to develop a lead sampling plan that will govern the collection and analysis of drinking water samples. Samples must then be sent to a certified testing laboratory for analysis.

The Barrington School District has completed testing at all three of our buildings, including the Avon Elementary School, Woodland Middle School and the Board of Education office. The following chart contains the results from those outlets where the sample was above the standard of 15.5 parts per billion for lead content. It details the actual lead level detected and outlines the remedial action to be taken.

<u>Sample Location</u>	<u>Sample Result ($\mu\text{g/L}$)</u>	<u>Remedial Action Taken</u>
Avon – B16 (Faucet)	50.4	Signage posted for Faucet
Woodland – B13	50.4	Removed from service
Woodland – Boy's Locker Room Office	39.6	Signage posted for Handwashing Only